



Ref. Certif. No.

FR_713498/M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)

Name and address of the applicant

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF3

Model / Type Ref.

RCCB 2P
Series TX³, RX³, DX³.

Additional information (if necessary may also be reported on page 2)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010 +A1:2012 +A2:2013
IEC 61008-2-1:1990

As shown in the Test Report Ref. No. which forms part of this Certificate

TR n° 22971744-802932, 22971744-802932/1 to /6
TR n° 22971744-802925, 22971744-802925/1 to /34

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

Name and address of the factories:

LEGRAND ELEKTRIK SANAYI A.S
GOSB GEBZE ORGANIZE SANAYI BOLGESI
IHSAN DEDE CADDESİ N°112
41480 GEBZE KOCAELI – TURKEY

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES - FRANCE

LEGRAND FRANCE
290 AVENUE DE COLMAR
67100 STRASBOURG - FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2025

Signature: 

ANNEX

References, ratings and main characteristics:

References TX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
4115 52 4119 10	16 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
LG3480	25 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A

References TX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
LG3481	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000 A
4115 59 4119 11	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4115 60 4119 12	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4115 61 4119 13	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
4115 62 4119 14	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
LG1225	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
LG3482	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
4115 64	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
4115 65	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
4115 66	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
4115 67	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
LG1226	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
LG3483	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4115 74	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4115 75 4119 22	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4115 76 4119 23	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
4115 77 4119 24	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
LG1227	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
LG3484	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
4115 79	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
4115 80	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG1228	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
LG1229	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
LG1230	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References TX ³ Germanic series	I _n (A)	U _n (V~)	IΔ _n (mA)	Type	I _m	IΔ _m	I _{nc}	IΔ _c
4115 02	16 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
LG1210	25 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A

References TX ³ Germanic series	I _n (A)	U _n (V~)	IΔ _n (mA)	Type	I _m	IΔ _m	I _{nc}	IΔ _c
LG3450	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4115 09	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4115 10	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4115 11	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
41151 2	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
4115 13	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG3451	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
41151 9	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4115 20	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4115 21	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
4115 22	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
4115 23	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
LG3452	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4115 29	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4115 30	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4115 31	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
4115 32	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
4115 33	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
LG3453	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG1211	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG1212	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG1213	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
LG1214	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
LG1215	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References TX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
LG3485	16 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1231	25 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1232	40 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1233	63 A	230V~	100 mA	A-S	630 A	1000 A	10000A	10000A
LG1234	80 A	230V~	100 mA	A-S	800 A	1000 A	10000A	10000A
LG1235	100 A	230V~	100 mA	A-S	1000 A	1000 A	10000A	10000A
LG3486	16 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
LG1236	25 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
LG1237 4119 27	40 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
4115 87 4119 28	63 A	230V~	300 mA	A-S	630 A	1000 A	10000A	10000A
LG1238	80 A	230V~	300 mA	A-S	800 A	1000 A	10000A	10000A
LG1239	100 A	230V~	300 mA	A-S	1000 A	1000 A	10000A	10000A
LG3487	16 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1240	25 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1241	40 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1242	63 A	230V~	500 mA	A-S	630 A	1000 A	10000A	10000A
LG1243	80 A	230V~	500 mA	A-S	800 A	1000 A	10000A	10000A
LG1244	100 A	230V~	500 mA	A-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References serie TX ³ Germanic	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3454	16 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG1216	25 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG1217	40 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
4115 39	63 A	230V~	100 mA	AC-S	630 A	1000 A	10000A	10000A
LG1218	80 A	230V~	100 mA	AC-S	800 A	1000 A	10000A	10000A
LG1219	100 A	230V~	100 mA	AC-S	1000 A	1000 A	10000A	10000A
LG3455	16 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
LG1220	25 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
LG1221	40 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
4115 47	63 A	230V~	300 mA	AC-S	630 A	1000 A	10000A	10000A
LG1222	80 A	230V~	300 mA	AC-S	800 A	1000 A	10000A	10000A
LG1223	100 A	230V~	300 mA	AC-S	1000 A	1000 A	10000A	10000A
LG3456	16 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3457	25 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3458	40 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3459	63 A	230V~	500 mA	AC-S	630 A	1000 A	10000A	10000A
LG3460	80 A	230V~	500 mA	AC-S	800 A	1000 A	10000A	10000A
LG3461	100 A	230V~	500 mA	AC-S	1000 A	1000 A	10000A	10000A

References TX ³ Germanic series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG7216	16 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7217	25 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7218	40 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7219	63 A	127/220V~	30 mA	A	630 A	1000 A	10000A	10000A
LG7220	80 A	127/220V~	30 mA	A	800 A	1000 A	10000A	10000A
LG7221	100 A	127/220V~	30 mA	A	1000 A	1000 A	10000A	10000A
LG7222	16 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
LG7223	25 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
LG7224	40 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
LG7225	63 A	127/220V~	300 mA	A	630 A	1000 A	10000A	10000A
LG7226	80 A	127/220V~	300 mA	A	800 A	1000 A	10000A	10000A
LG7227	100 A	127/220V~	300 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

References TX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
LG7204	16 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7205	25 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7206	40 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7207	63 A	127/220V~	30 mA	AC	630 A	1000 A	10000A	10000A
LG7208	80 A	127/220V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG7209	100 A	127/220V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG7210	16 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG7211	25 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG7212	40 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG7213	63 A	127/220V~	300 mA	AC	630 A	1000 A	10000A	10000A
LG7214	80 A	127/220V~	300 mA	AC	800 A	1000 A	10000A	10000A
LG7215	100 A	127/220V~	300 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

References TX ³ Germanic other range series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG7570	16 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
LG7571	25 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A

References TX ³ Germanic other range series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG7608	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7609	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7610	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7611	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
LG7612	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
LG7613	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0743	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0744	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0745	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0746	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
8LG0747	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
8LG0748	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
LG7572	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG7573	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG7574	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG7575	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
LG7576	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
LG7577	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
8LG0832	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0833	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0834	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0835	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
8LG0836	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
8LG0837	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2025

Signature:

Julien Gauthier
LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
92260 FONTENAY AUX ROSES
Certification Officer

ANNEX

References TX ³ Germanic other range series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
LG7562	16 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
LG7563	25 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A

References TX ³ Germanic other range series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
LG7602	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7603	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7604	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7605	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
LG7606	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG7607	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0737	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0738	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0739	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0740	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
8LG0741	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
8LG0742	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
LG7564	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG7565	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG7566	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG7567	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
LG7568	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
LG7569	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
8LG0808	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0809	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0810	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0811	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
8LG0812	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
8LG0813	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Signature
LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
13 avenue du Général Leclerc
92260 FONTENAY-AUX-ROSES

Date: 23/06/2025

Signature: **Julien GAUTIER**
Certification Officer

ANNEX

References TX ³ Germanic other range series	I _n (A)	U _n (V~)	I _{Δn} (mA)	Type	I _m	I _{Δm}	I _{nc}	I _{Δc}
8LG0838	16 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0839	25 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0840	40 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0841	63 A	230V~	100 mA	A-S	630 A	1000 A	10000A	10000A
8LG0842	80 A	230V~	100 mA	A-S	800 A	1000 A	10000A	10000A
8LG0843	100 A	230V~	100 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0844	16 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0845	25 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0846	40 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0847	63 A	230V~	300 mA	A-S	630 A	1000 A	10000A	10000A
8LG0848	80 A	230V~	300 mA	A-S	800 A	1000 A	10000A	10000A
8LG0849	100 A	230V~	300 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0850	16 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0851	25 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0852	40 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0853	63 A	230V~	500 mA	A-S	630 A	1000 A	10000A	10000A
8LG0854	80 A	230V~	500 mA	A-S	800 A	1000 A	10000A	10000A
8LG0855	100 A	230V~	500 mA	A-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References TX ³ Germanic other range series	I _n (A)	U _n (V~)	IΔ _n (mA)	Type	I _m	IΔ _m	I _{nc}	IΔ _c
8LG0814	16 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0815	25 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0816	40 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0817	63 A	230V~	100 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0818	80 A	230V~	100 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0819	100 A	230V~	100 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0820	16 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0821	25 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0822	40 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0823	63 A	230V~	300 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0824	80 A	230V~	300 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0825	100 A	230V~	300 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0826	16 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0827	25 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0828	40 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0829	63 A	230V~	500 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0830	80 A	230V~	500 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0831	100 A	230V~	500 mA	AC-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

References TX ³ Germanic other range series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
LG7596	16 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7597	25 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7598	40 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
LG7599	63 A	127/220V~	30 mA	A	630 A	1000 A	10000A	10000A
LG7600	80 A	127/220V~	30 mA	A	800 A	1000 A	10000A	10000A
LG7601	100 A	127/220V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0886	16 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0887	25 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0888	40 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0889	63 A	127/220V~	300 mA	A	630 A	1000 A	10000A	10000A
8LG0890	80 A	127/220V~	300 mA	A	800 A	1000 A	10000A	10000A
8LG0891	100 A	127/220V~	300 mA	A	1000 A	1000 A	10000A	10000A

References TX ³ Germanic other range series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
LG7590	16 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7591	25 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7592	40 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG7593	63 A	127/220V~	30 mA	AC	630 A	1000 A	10000A	10000A
LG7594	80 A	127/220V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG7595	100 A	127/220V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0880	16 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0881	25 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0882	40 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0883	63 A	127/220V~	300 mA	AC	630 A	1000 A	10000A	10000A
8LG0884	80 A	127/220V~	300 mA	AC	800 A	1000 A	10000A	10000A
8LG0885	100 A	127/220V~	300 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature:

Jean Gauthier
LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 468 365 121
F - 92266 FONTENAY-AUX-ROSES
Certification Officer

ANNEX

References TX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3417	16 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
LG3418	25 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A

References TX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG 3419	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4030 35	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4030 36	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
LG1250	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
LG1251	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
LG1252	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
LG3420	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG3421	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG3422	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG3423	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
LG3424	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
LG3425	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
LG3426	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG3427	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG3428	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG3429	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
LG3430	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
LG3431	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
LG3432	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG3433	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG3434	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG3435	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
LG3436	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
LG3437	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature:

Julien Gauthier
LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
92260 FONTENAY AUX ROSES
Certification Officer

ANNEX

References TX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG1255	16 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
LG1256	25 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A

References TX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3400	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4030 00 4030 32	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4030 01 4030 33	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4030 02	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
LG1253	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG1254	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG3401	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
LG3406	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
LG3407	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
LG3408	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
LG3403	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
LG3404	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
LG3405	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4030 38	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4030 39	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4030 40	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
LG3409	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
LG3410	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
LG3411	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG3412	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG3413	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG3414	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
LG3415	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
LG3416	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References RX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG2309	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4020 36	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4025 35 4020 37	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4025 36 4020 38	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
LG2310	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
LG2311	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
LG2312	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG2313	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG2314	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG2315	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
LG2316	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
LG2317	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
LG2318	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG2319	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG2320 4025 37	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
LG2321 4025 38	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
LG2322	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
LG2323	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
LG2324	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG2325	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG2326	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG2327	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
LG2328	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
LG2329	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

References RX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG2300	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4020 24	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4020 25	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4020 26	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
4020 27	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG1202	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG2301	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4020 28	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4020 29	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4020 30	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
LG1203	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
LG1204	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
LG2302	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4020 32	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4020 33	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4020 34	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
LG1205	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
LG1206	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
LG2303	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG2304	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG2305	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG2306	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
LG2307	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
LG2308	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References RX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG7370	16 A	230V~	30 mA	A	500 A	1000 A	6000A	6000A
4020 59	25 A	230V~	30 mA	A	500 A	1000 A	6000A	6000A
4020 60	40 A	230V~	30 mA	A	500 A	1000 A	6000A	6000A
LG7371	63 A	230V~	30 mA	A	630 A	1000 A	6000A	6000A
LG7372	80 A	230V~	30 mA	A	800 A	1000 A	6000A	6000A
LG7373	100 A	230V~	30 mA	A	1000 A	1000 A	6000A	6000A
LG7366	16 A	230V~	30 mA	AC	500 A	1000 A	6000A	6000A
4020 56	25 A	230V~	30 mA	AC	500 A	1000 A	6000A	6000A
4020 57	40 A	230V~	30 mA	AC	500 A	1000 A	6000A	6000A
LG7367	63 A	230V~	30 mA	AC	630 A	1000 A	6000A	6000A
LG7368	80 A	230V~	30 mA	AC	800 A	1000 A	6000A	6000A
LG7369	100 A	230V~	30 mA	AC	1000 A	1000 A	6000A	6000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature:


LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre 508 180 172
33 avenue du Général Leclerc
92260 FONTENAY-AUX-ROSES

Certification Officer

ANNEX

References RX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG2340	16 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
4020 86	25 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
4020 87	40 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
4020 88	63 A	127/220V~	30 mA	AC	630 A	1000 A	10000A	10000A
LG2341	80 A	127/220V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG2342	100 A	127/220V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG2343	16 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG2344	25 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG2345	40 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG2346	63 A	127/220V~	300 mA	AC	630 A	1000 A	10000A	10000A
LG2347	80 A	127/220V~	300 mA	AC	800 A	1000 A	10000A	10000A
LG2348	100 A	127/220V~	300 mA	AC	1000 A	1000 A	10000A	10000A

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
4115 50	16 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
LG1040	25 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3330	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4115 54	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4115 55	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4115 56	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
4115 57	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
LG1041	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
LG3331	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG1042	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG1043	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
LG1044	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
LG1045	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
LG1046	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
LG3332	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4115 69	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4115 70	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4115 71	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
4115 72	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
LG1047	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
LG3333	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG1048	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG1049	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
LG1050	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
LG1051	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
LG1052	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
4115 00	16 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
4115 01	25 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3300	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4115 04	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4115 05	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4115 06	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
4115 07	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
4115 08	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG3301	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4115 14	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4115 15	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4115 16	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
4115 17	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
LG1060	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
LG3302	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4115 24	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4115 25	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4115 26	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
4115 27	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
4115 28	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
LG3303	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG1061	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG1062	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
LG1063	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
LG1064	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
LG1065	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE

33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr

Date: 23/06/2025

Signature: 
Certification Officer



ANNEX

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3334	16 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1066	25 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1067	40 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
LG1068	63 A	230V~	100 mA	A-S	630 A	1000 A	10000A	10000A
LG1069	80 A	230V~	100 mA	A-S	800 A	1000 A	10000A	10000A
LG1070	100 A	230V~	100 mA	A-S	1000 A	1000 A	10000A	10000A
LG3335	16 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
LG1071	25 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
LG1072	40 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
4115 84	63 A	230V~	300 mA	A-S	630 A	1000 A	10000A	10000A
LG1073	80 A	230V~	300 mA	A-S	800 A	1000 A	10000A	10000A
LG1074	100 A	230V~	300 mA	A-S	1000 A	1000 A	10000A	10000A
LG3336	16 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1075	25 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1076	40 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
LG1077	63 A	230V~	500 mA	A-S	630 A	1000 A	10000A	10000A
LG1078	80 A	230V~	500 mA	A-S	800 A	1000 A	10000A	10000A
LG1079	100 A	230V~	500 mA	A-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3304	16 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG1080	25 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG1081	40 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
LG1082	63 A	230V~	100 mA	AC-S	630 A	1000 A	10000A	10000A
LG1083	80 A	230V~	100 mA	AC-S	800 A	1000 A	10000A	10000A
4115 37	100 A	230V~	100 mA	AC-S	1000 A	1000 A	10000A	10000A
LG3305	16 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
LG1084	25 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
LG1085	40 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
4115 43	63 A	230V~	300 mA	AC-S	630 A	1000 A	10000A	10000A
LG1086	80 A	230V~	300 mA	AC-S	800 A	1000 A	10000A	10000A
LG1087	100 A	230V~	300 mA	AC-S	1000 A	1000 A	10000A	10000A
LG3306	16 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3307	25 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3308	40 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
LG3309	63 A	230V~	500 mA	AC-S	630 A	1000 A	10000A	10000A
LG3310	80 A	230V~	500 mA	AC-S	800 A	1000 A	10000A	10000A
LG3311	100 A	230V~	500 mA	AC-S	1000 A	1000 A	10000A	10000A

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3381	16 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
4118 22	25 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
4118 23	40 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
4118 24	63 A	127/220V~	30 mA	A	630 A	1000 A	10000A	10000A
4118 25	80 A	127/220V~	30 mA	A	800 A	1000 A	10000A	10000A
4118 26	100 A	127/220V~	30 mA	A	1000 A	1000 A	10000A	10000A
LG3382	16 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
4118 27	25 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
4118 28	40 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
4118 29	63 A	127/220V~	300 mA	A	630 A	1000 A	10000A	10000A
4118 30	80 A	127/220V~	300 mA	A	800 A	1000 A	10000A	10000A
4118 31	100 A	127/220V~	300 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

References DX ³ series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG3383	16 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG3384	25 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG3385	40 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
LG3386	63 A	127/220V~	30 mA	AC	630 A	1000 A	10000A	10000A
LG3387	80 A	127/220V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG3388	100 A	127/220V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG3389	16 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG3390	25 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG3391	40 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
LG3392	63 A	127/220V~	300 mA	AC	630 A	1000 A	10000A	10000A
LG3393	80 A	127/220V~	300 mA	AC	800 A	1000 A	10000A	10000A
LG3394	100 A	127/220V~	300 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
Certification Officer



ANNEX

Characteristics:

Characteristics	Values
Independent of line voltage	yes
Rated voltage	230 V~ and 127/220V~
Rated frequency	50 Hz
Rated current	16A, 25A, 40A, 63A, 80A, 100A
Rated residual operating current	0.010, 0.030, 0.100, 0.300, 0.500 A
Type	AC – AC-S – A – A-S
Delay time	without, with (type S)
Nature of supply	~
Number of poles	2
Rated insulation voltage	250 V
Rated impulse withstand voltage, Uimp (V)	4 000V
Utilisation range temperature (°C)	-25 °C à/to +40 °C
Breaking and making capacity	500 A, 630 A, 800 A, 1000 A
Rated residual making and breaking capacity	1 000 A
Rated residual operating current	10 000 A, 6000 A (Range Vivienda)
Rated conditional residual short-circuit current	10 000 A, 6000 A (Range Vivienda)
Grid distance (short-circuit tests)	35 mm
IP degree	IP20
Material group	II
Method of installation	panel board, distribution board, on rail
Type of terminals	pillar terminal
Nominal diameter of thread	5 mm



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date:23/06/2025

Signature: 
 Certification Officer

