

# CERTIFICATE

No. U6 097386 0475 Rev. 00

**Holder of Certificate:** LEDVANCE GmbH

Parkring 1-5  
85748 Garching  
GERMANY

**Certification Mark:**



**Product:**


**Fixed general purpose luminaires  
(LED Fixed Luminaire)**

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:**

64142235002001

**Date,** 2024-07-17



( Taylor Yao )

# CERTIFICATE

No. U6 097386 0475 Rev. 00

**Model(s):**

For Profile surface part:

OFFICE LINEAR SF V 34W PS 1124 WT;  
OFFICE LINEAR SF V 34W PS 1124 BK;  
OFFICE LINEAR SF V 34W PS 1124 GY;  
OFFICE LINEAR SF V 34W PS 1124 WT DALI;  
OFFICE LINEAR SF V 34W PS 1124 BK DALI;  
OFFICE LINEAR SF V 34W PS 1124 GY DALI;

For Lighting module part:

OFFICE LINEAR V 2CCT PRISM;  
OFFICE LINEAR V 2CCT UGR19;  
OFFICE LINEAR V 2CCT OPAL

**Brand Name:**

LEDVANCE

**Parameters:**

Rated Voltage: 220-240VAC [for Profile surface part];

80-86VDC [for Lighting module part]

Rated Frequency: 50/60Hz [for Profile surface part]

Rated Power: Max.34W

Protection Class: I

Degree of Protection: IP20 [for whole luminaire]

Blue Light Risk Group: RG0

ta: 40°C

**Tested  
according to:**

EN IEC 60598-2-1:2021

EN IEC 60598-1:2021/A11:2022

**Production  
Facility(ies):**

090247, 101065