

# LICENCE

**No. 23586**

Issued to:  
Applicant:  
**Legrand Group Belgium N.V.**  
**Hector Henneaulaan 366**  
**1930 Zaventem**  
**Belgium**

Licensee:  
**Legrand Group Belgium N.V.**  
**Hector Henneaulaan 366**  
**1930 Zaventem**  
**Belgium**



Product : circuit-breakers for overcurrent protection  
Trade name(s) : LEGRAND  
Type(s)/model(s) : Series DX<sup>3</sup>

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 178

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on : 06/03/2026

  
ir. C. Lana,  
Certification Manager



**005-PROD**  
**ISO/IEC 17065:2012**

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



**SGS Belgium NV-Division SGS CEBEC**  
**Business Riverside Park**  
**Bld Internationalelaan 55 Build. A**  
**B-1070 Brussels**  
**Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36**

This certificate is issued by the company under its General Conditions for Certification Services accessible at [http://www.sgs.com/terms\\_and\\_conditions.htm](http://www.sgs.com/terms_and_conditions.htm). Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



## SPECIFICATION OF THE CERTIFIED PRODUCT

### Product data

Product	:	circuit-breakers for overcurrent protection
Trade name(s)	:	LEGRAND
Type(s)/Model(s)	:	Series DX <sup>3</sup>
number of poles	:	2P, 3P & 4P
rated voltage (Un)	:	400 V
nature of supply	:	AC
rated frequency	:	50 Hz
range of instantaneous tripping overcurrent (curve)	:	C
rated current (In)	:	2 A up to 63 A
rated conditional short-circuit current (Ics)	:	7500 A
rated short-circuit current (Icn)	:	10000 A
method of mounting	:	DIN-RAIL fixation
terminals	:	pillar terminals
energy limiting class	:	3
safety distance 'a'	:	35 mm

### Additional information

See Appendix

## TESTS

### Test requirements

NBN EN 60898-1 based on EN 60898-1:2019

### Test results

The test results are laid down in certification file ref.635551/01



### Remarks


This certificate is based on certificate ref. IT-24113 and test report(s) ref. PB23-0089282-01-00 and from PB23-0089282-01-01 to PB23-0089282-01-62

### Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Silvio Piras - 06/03/2026

Certification Manager :



2026-03-06



## FACTORY LOCATION(S)

BTicino Spa  
Via delle Industrie 22  
80059 TORRE DEL GRECO (NA)  
Italy

**Products References:****MCBs series DX<sup>3</sup>:**

Type	2P 400 V	3P 400 V	4P 400 V	Icn
C 2A	409196	409248	-	10000 A
C 4A	409198	409250	409332	10000 A
C 6A	409199	409251	409333	10000 A
C 10A	409200	409252	409334	10000 A
C 16A	409202	409254	409336	10000 A
C 20A	409203	409255	409337	10000 A
C 25A	409204	409256	409338	10000 A
C 32A	409205	409257	409339	10000 A
C 40A	409206	409258	409340	10000 A
C 50A	409207	409259	409341	10000 A
C 63A	409208	409260	409342	10000 A

