

LICENCE

No. 23462

Issued to:
Applicant:
Legrand Group Belgium N.V.
Hector Henneaulaan 366
1930 Zaventem
Belgium

Licensee:
Legrand Group Belgium N.V.
Hector Henneaulaan 366
1930 Zaventem
Belgium



Product : socket-outlets (2-pole)
Trade name(s) : LEGRAND
Type(s)/model(s) : Series SOLIROC (See appendix)

The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.


SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 178

SGS CEBEC hereby grants the right to use the CEBEC certification mark

The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on : 26/09/2025


ir. C. Lana,
Certification Manager



005-PROD
ISO/IEC 17065:2012

© Only integral publication of this certificate, including the annex, is allowed

This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bld Internationelelaan 55 Build. A
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	: socket-outlets (2-pole)
Trade name(s)	: LEGRAND
Type(s)/Model(s)	: Series SOLIROC (See appendix)
rated current (In)	: 16 A
rated voltage (Un)	: 250 Vac
earthing	: with pin-earthing
standard sheet	: V
existence of shutters	: with shutters
degree of protection	: IP 40: Without cover IP 55 with keyed cover
resistance to impact (IK)	: IK 10
type of terminals	: screwles (rigid and flexible)
method of mounting	: flush type surface type with box 0 778 90 or 0 778 92
method of installation	: design A
certification mark	: complies with the requirements.
markings	: are shown on the body

Additional information

See Appendix

TESTS

Test requirements

NBN C 61-112-1 ed. 2017 based on IEC 60884-1:2002 + A1:2006 + A2:2013

Test results

The test results are laid down in certification file ref.635039/01

Remarks

This certificate is based on certificate ref. FR_720392 and test reports ref. 635039.01 and 21108236-797224

Conclusion

The examination proved that all certification requirements were met.

Reviewed by, project leader : Luigi Zanutto - 26/09/2025

Certification Manager :



2025-09-26

FACTORY LOCATION(S)

Legrand France
128, avenue du Maréchal de Lattre de Tassigny
87045 LIMOGES CEDEX
France

General product information and other remarks:

Description	Reference
Socket outlet 2P+E with shutters, screwless terminals and cover	0 778 31
Socket outlet 2P+E with shutters, screwless terminals without cover	0 778 32
Socket outlet 2P+E with shutters, screwless terminals and keyed cover	0 778 33

Boxes

Description	Reference
Box 1 gang	0 778 90
Box 2 gang	0 778 92

Frames

	Reference
Frame 1 gang	0 802 51
Frame 1 gang with short claws	670 635
Frame 1 gang with long claws	670 630

Cover plates

	Reference
Cover plate 1 gang	0 778 51
Cover plate 2 gangs horizontal or vertical centres 71 mm	0 778 52
Cover plate 3 gangs horizontal or vertical centres 71 mm	0 778 53