

CERTIFICATE

No. U6 097386 0049 Rev. 00

Holder of Certificate: **LEDVANCE GmbH**

Parkring 29-33
85748 Garching
GERMANY

Certification Mark:




Product: **Power supplies
(LED POWER SUPPLY)**

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.: 64142205000801

Date, 2020-06-04



(Taylor Yao)

CERTIFICATE

No. U6 097386 0049 Rev. 00

Model(s):

DR DALI-PFM-26/220-240/700;
DR DALI-PFM-44/220-240/1050;
DR DALI-PFM-60/220-240/1A4;
LVED SUP 60/220-240/1A4 DIM;
DR DALI-SUP-45/220-240/24;
LVED SUP 45/220-240/24 DIM;
DR DALI-SUP-80/220-240/24;
LVED SUP 80/220-240/24 DIM;
DR DALI-SUP-150/220-240/24;
LVED SUP 150/220-240/24 DIM

Brand Name:

LEDVANCE

**Parameters:**

Rated Input Voltage: See below table for details

Rated Frequency: See below table for details

Rated Input Current: See below table for details

Rated Output: See below table for details

Protection against Electric Shock: Class II (for independent type); SELV

Degree of Protection: IP20 (for independent type)

Method of Installation: See below table for details

Type of Output: See below table for details

ta: See below table for details

tc: See below table for details

CERTIFICATE

No. U6 097386 0049 Rev. 00

Model No.	Rated Input Voltage (V)/Rated Frequency (Hz)	Rated Input Current (A) Max.	Output Voltage (VDC)	Irated (mA)	Uout (VDC)	Prated (W)	Value Of ta; tc (°C)	Type of Output	Method of Installation
DR DALI-PFM-26/220-240/700	220-240VAC; 50/60Hz; 196-245VDC	0.176 (AC); 0.15 (DC)	9-52	150	60	7.8	ta: 50; tc: 85	Constant Current Type	Independent (with endcap); Built-in (without endcap)
				200		10.4			
				250		13			
				300		15.6			
				350		18.2			
				400		20.8			
			9-47.5	450		23.4			
				500		26			
				550		26.1			
				600		26.1			
				650		26			
				700		26.3			
DR DALI-PFM-44/220-240/1050	220-240VAC; 50/60Hz; 196-245VDC	0.275 (AC); 0.24 (DC)	9-52	700	60	36.4	ta: 50; tc: 90	Constant Current Type	Independent (with endcap); Built-in (without endcap)
				750		39			
				800		41.6			
			9-49	850		41.7			
				900		44.1			
			9-46	950		43.7			
			9-44	1000		44			
DR DALI-PFM-60/220-240/1A4; LVED SUP 60/220-240/1A4 DIM	220-240VAC; 50/60Hz; 196-245VDC	0.385 (AC); 0.32 (DC)	9-52	1050	60	44.1	ta: 50; tc: 90	Constant Current Type	Independent (with endcap); Built-in (without endcap)
				700		36.4			
				750		39			
				800		41.6			
				850		44.2			
				900		46.8			
				950		49.4			
				1000		52			
			9-50	1050		54.6			
				1100		57.2			
				1150		59.8			
				1200		60			
				1250		60			
				1300		59.8			
				1350		59.4			
				1400		60.2			



CERTIFICATE

No. U6 097386 0049 Rev. 00

Model No.	Rated Input Voltage (V)/Rated Frequency (Hz)	Rated Input Current (A) Max.	Urated (VDC)	Output Current (A)	Prated (W)	Value of ta; tc (°C)	Type of Output	Method of Installation
DR DALI-SUP-45/220-240/24; LVED SUP 45/220-240/24 DIM	220-240VAC; 50/60Hz	0.275	24	1.88	45	ta: 50; tc: 85	Constant Voltage Type	Independent
DR DALI-SUP-80/220-240/24; LVED SUP 80/220-240/24 DIM		0.462	24	3.33	80	ta: 45; tc: 85		
DR DALI-SUP-150/220-240/24; LVED SUP 150/220-240/24 DIM		0.825	24	6.25	150	ta: 45; tc: 85		

Tested according to:

EN 61347-2-13:2014/A1:2017
EN 61347-1:2015
EN 62384:2006/A1:2009

Production Facility(ies):

059266