



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-165-11**

Valid from: 2021 07 07
until: 2023 07 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Socket outlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 37981, 35803**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2021 06 17



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
IEC 60309-1:1999 + A1:2005 + A2:2012
IEC 60309-2:1999 + A1:2005 + A2:2012

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Socket outlets for industrial purposes

Type designation:

Rating:

382

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
flanged socket outlet
with minor key

383

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
flanged socket outlet
with minor key

Trademark:

PCE / ELCEE / METECEE

PCE / ELCEE / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

182

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet
with minor key

PCE / ELCEE / METECEE

183

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet
with minor key

PCE / ELCEE / METECEE

362

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
flanged socket outlet
without minor key

PCE / ELCEE / METECEE

363

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
flanged socket outlet
without minor key

PCE / ELCEE / METECEE

162

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet
without minor key

PCE / ELCEE / METECEE

163

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet
without minor key

PCE / ELCEE / METECEE

982

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet (looped through)
with minor key

PCE / ELCEE / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

983

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet (looped through)
with minor key

PCE / ELCEE / METECEE

962

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet (looped through)
without minor key

PCE / ELCEE / METECEE

963

Rated current: 16 A
Insulation voltage: 50 V
IP44 or IP44/IP54
wall mounted socket outlet (looped through)
without minor key

PCE / ELCEE / METECEE

3822

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
flanged socket outlet
with minor key

PCE / ELCEE / METECEE

3832

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
flanged socket outlet
with minor key

PCE / ELCEE / METECEE

1822

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet
with minor key

PCE / ELCEE / METECEE

1832

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet
with minor key

PCE / ELCEE / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

3622

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
flanged socket outlet
without minor key

PCE / ELCEE / METECEE

3632

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
flanged socket outlet
without minor key

PCE / ELCEE / METECEE

1622

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet
without minor key

PCE / ELCEE / METECEE

1632

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet
without minor key

PCE / ELCEE / METECEE

9822

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet (looped through)
with minor key

PCE / ELCEE / METECEE

9832

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet (looped through)
with minor key

PCE / ELCEE / METECEE

9622

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet (looped through)
without minor key

PCE / ELCEE / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

9632

PCE / ELCEE / METECEE

Rated current: 16 A
Insulation voltage: 50 V
IP67 or IP66/IP67
wall mounted socket outlet (looped through)
without minor key

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

Typelist

| Type | Pole | Position minor key [h] | Rated operating-voltage [V] | Frequency [Hz] | Minor key |
|---|------|------------------------|-----------------------------|----------------|-----------|
| 162 362 962 | 2 | - | 20-25 | 50 and 60 | without |
| 182 382 982 | | 12 | 40-50 | 50 and 60 | with |
| | | 4 | 20-25 and 40-50 | 100-200 | |
| | | 2 | | 300 | |
| | | 3 | | 400 | |
| | | 11 | | >400-500 | |
| 10 | | DC | | | |
| 163 363 963 | 3 | - | 20-25 | 50 and 60 | without |
| 183 383 983 | | 12 | 40-50 | 50 and 60 | with |
| | | 4 | 20-25 and 40-50 | 100-200 | |
| | | 2 | | 300 | |
| | | 3 | | 400 | |
| | | 11 | | >400-500 | |
| 10 | | DC | | | |
| 1622 3622 9622 | 2 | - | 20-25 | 50 and 60 | without |
| 1822 3822 9822 | | 12 | 40-50 | 50 and 60 | with |
| | | 4 | 20-25 and 40-50 | 100-200 | |
| | | 2 | | 300 | |
| | | 3 | | 400 | |
| | | 11 | | >400-500 | |
| 10 | | DC | | | |
| 1632 3632 9632 | 3 | - | 20-25 | 50 and 60 | without |
| 1832 3832 9832 | | 12 | 40-50 | 50 and 60 | with |
| | | 4 | 20-25 and 40-50 | 100-200 | |
| | | 2 | | 300 | |
| | | 3 | | 400 | |
| | | 11 | | >400-500 | |
| 10 | | DC | | | |

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.