



ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **43-167-14**

Valid from: 2021 07 07
until: 2023 07 07

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **PC Electric Ges.m.b.H.**
Diesseits 145
4973 St. Martin im Innkreis
Austria

Product: **Appliance inlets for industrial purposes**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **TGM-VA EE 35180**

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer

Wien, 2021 06 17



OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.



Manufacturer:

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Factory location(s):

PC Electric Ges.m.b.H.
Diesseits 145
4973 St. Martin im Innkreis
Austria

Tested and certified according to:

ÖVE/ÖNORM EN 60309-1:2013-03-01
ÖVE/ÖNORM EN 60309-2:2013-03-01
IEC 60309-1:1999 + A1:2005 + A2:2012
IEC 60309-2:1999 + A1:2005 + A2:2012

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

Product: Appliance inlets for industrial purposes

Type designation:

Rating:

Trademark:

533

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

633

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

733

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

77733

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

534

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

634

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

734

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

77734

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

535

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

635

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

735

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

77735

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

5332

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6332

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7332

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

777332

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

5342

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6342

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7342

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

777342

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

5352

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

6352

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

7352

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet sloping

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

777352

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 67 or IP 66/IP 67
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

5331

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 44
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

53321

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 44
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

5341

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 44
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

53421

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 44
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

5351

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 44
with pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

53521

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 44
without pilot contact, wall mounted appliance-inlet

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

6331

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 44
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

63321

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 44
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

6341

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 44
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

63421

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 44
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

6351

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 44
with pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

63521

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 44
without pilot contact, flanged appliance-inlet straight

PCE / ELCEE / SIROX / METECEE

777331

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 44
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

7773321

Rated current: 63 A
Insulation voltage: 690 V
2P+PE
IP 44
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

777341

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 44
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

7773421

Rated current: 63 A
Insulation voltage: 690 V
3P+PE
IP 44
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

777351

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 44
with pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

7773521

Rated current: 63 A
Insulation voltage: 690 V
3P+N+PE
IP 44
without pilot contact, flanged appliance-inlet angled

PCE / ELCEE / SIROX / METECEE

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz
533 633 733 77733 5332 6332 7332 777332	63	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	>50 - 250	DC
		4	100 – 130	50 and 60
		6	200 – 250	50 and 60
		7	480 – 500	50 and 60
		8	>250	DC
		9	380 – 415	50 and 60
		10	>50	>100 - 300
		12	Supply from an isolating transformer	50 and 60
534 634 734 77734 5342 6342 7342 777342	63	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	380 440	50 60
		4	100 – 130	50 and 60
		5	600 – 690	50 and 60
		6	380 – 415	50 and 60
		7	480 - 500	50 and 60
		9	200 – 250	50 and 60
		10	>50	>100 - 300
		11	440 – 460	60
		12	Supply from an isolating transformer	50 and 60
		535 635 735 77735 5352 6352 7352 777352	63	1
2	>50			>300 - 500
3	220/380 250/440			50 60
4	57/100 – 75/130			50 and 60
5	347/600 – 400/690			50 and 60
6	200/346 – 240/415			50 and 60
7	277/480 – 288/500			50 and 60
9	120/208 – 144/250			50 and 60
10	>50			>100 - 300
11	250/440 – 265/460			60
12	Supply from an isolating transformer			50 and 60

533, 633, 733, 77733, 534, 634, 734, 77734, 535, 635, 735, 77735with pilot contact
5332, 6332, 7332, 777332, 5342, 6342, 7342, 777342, 5352, 6352, 7352, 777352 ..without pilot contact

Version ...k:

Special model with compact housing (possible for types of Series 5.., 6.. and 777..).

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

Accessories:

ts7632 •

		colour	
		g	- grey
		*	- reserved for additional colours
			Water protection cap IP67 or IP66/67

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.

Typelist

Type	Rated current A	Earthing contact pos. h	Rated operating voltage V	Frequency Hz
5331 6331 777331 53321 63321 7773321	63	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	>50 - 250	DC
		4	100 – 130	50 and 60
		6	200 – 250	50 and 60
		7	480 – 500	50 and 60
		8	>250	DC
		9	380 – 415	50 and 60
		10	>50	>100 - 300
		12	Supply from an isolating transformer	50 and 60
5341 6341 777341 53421 63421 7773421	63	1	Other ratings	Other ratings
		2	>50	>300 - 500
		3	380 440	50 60
		4	100 – 130	50 and 60
		5	600 – 690	50 and 60
		6	380 – 415	50 and 60
		7	480 - 500	50 and 60
		9	200 – 250	50 and 60
		10	>50	>100 - 300
		11	440 – 460	60
		12	Supply from an isolating transformer	50 and 60
		5351 6351 777351 53521 63521 7773521	63	1
2	>50			>300 - 500
3	220/380 250/440			50 60
4	57/100 – 75/130			50 and 60
5	347/600 – 400/690			50 and 60
6	200/346 – 240/415			50 and 60
7	277/480 – 288/500			50 and 60
9	120/208 – 144/250			50 and 60
10	>50			>100 - 300
11	250/440 – 265/460			60
12	Supply from an isolating transformer			50 and 60

5331, 6331, 777331, 5341, 6341, 777341, 5351, 6351, 777351with pilot contact

53321, 63321, 7773321, 53421, 63421, 7773421, 53521, 63521, 7773521without pilot contact

Version ...k:

Special model with compact housing (possible for types of Series 5.., 6.. and 77..).

OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under www.bmdw.gv.at/akkreditierung.