

UKCA DECLARATION OF CONFORMITY No. 22.3186.06.22

We Hager Electro SAS
BP3
67215 OBERNAI CEDEX - FRANCE

Declare that the product(s)

Designation

MCCB H800 TM

Type reference(s)

HNK630U_HNK631U_HNK800U_HNK801U_HEK630U_HEK631U_
HEK800U_HEK801U

Trademark

Hager

is (are) in conformity with the relevant United Kingdom legislation:

- SI 2012/3032 Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012 (as amended)
- SI 2016/1091 Electromagnetic Compatibility (EMC) Regulations 2016 (as amended)
- SI 2016/1101 Electrical Equipment (safety) Regulations 2016 (as amended)

.....

.....

Standard(s) and/or relevant document(s) to which conformity is declared

Standard number + relevant amendments together with the edition dates

BS EN 60947-2:2017-10+A1:2020-02

BS EN IEC 63000:2018

If applicable, mention here for radio products, the data about notified body. See RE legislation - Annex VI - point 7

This declaration of conformity is issued under the sole responsibility of the manufacturer.

On behalf of Hager Electro SAS - BP3 - 67215 OBERNAI CEDEX - FRANCE

Name of signatory

Mr Eric Boivin

Function of signatory

Certification Manager

Place and date of issue

Obernai, 22th June 2022

Signature



UKCA DECLARATION OF CONFORMITY

No. 22.3186.06.22

Type references

Type reference	Description
HNK630U	MCCB H800 3 poles 630A Icu/Ics= 50/50kA TM
HNK631U	MCCB H800 4 poles 630A Icu/Ics= 50/50kA TM
HNK801U	MCCB H800 4 poles 800A Icu/Ics= 50/50kA TM
HNK800U	MCCB H800 3 poles 800A Icu/Ics= 50/50kA TM
HEK630U	MCCB H800 3 poles 800A Icu/Ics= 70/50kA TM
HEK631U	MCCB H800 4 poles 630A Icu/Ics= 70/50kA TM
HEK801U	MCCB H800 4 poles 800A Icu/Ics= 70/50kA TM
HEK800U	MCCB H800 3 poles 800A Icu/Ics= 70/50kA TM

UKCA DECLARATION OF CONFORMITY

No. 22.3186.06.22

Evidence (s)

Documents listed below have been used in order to establish the conformity to the essential requirements of the relevant legislation

Evidences approved by: Site:	Engineering Quality / Certification Obernai
Only designated standards published on GOV.UK (https://www.gov.uk/guidance/designated-standards) are used:	Yes
Scope and classification fully covers the product (case 1 of Hager Group risk analysis):	Yes
Comments :	
Hager Group risk analysis: (Only if there is at least one "No", then you have to explain how you cover the essential requirements and fill the document <u>DMS034433</u> - Hager Group risk analysis)	Risk analysis 22.1874.06.22
Certificate(s) / test report(s):	CB test certificate No. NL-65110 and Test report No. 2243599.65 Certificate No. KRC 5917-1c and KRC 15358f Certificate No. KRC 15235
Mark approval(s):	No marks
Product documentation :	See on Hager website
Comments:	BS EN Standard requirements are identical to EN Standard